

MINUTES OF MANCHESTER/SHORTSVILLE JOINT SEWERAGE SYSTEM MEETING AT
SHORTSVILLE VILLAGE HALL ON February 18, 2025

| | |
|------------------------|--|
| Present: Ernest Corino | Commissioner/Mayor, Village of Shortsville |
| Bill Henry | Trustee, Village of Manchester |
| Sharon Trimm | Trustee, Village of Shortsville |
| Mike Buttaccio | Deputy Commissioner/Mayor, Village of Manchester |
| Gordon Eddington | Eddington Environmental, LLC |

Recording Clerk: Amy Alexander Clerk-Treasurer, Village of Shortsville

The meeting was called to order by Commissioner Ernest Corino at 4:30 P.M.

The minutes of January 2025 meeting were prepared beforehand by the Recording Clerk and on motion of Trustee Henry, seconded by Trustee Trimm, voted and carried unanimously to accept as prepared and placed on file.

Deputy Commissioner Buttaccio presented the January 2025 Operation and Maintenance Treasurers Report. A motion was made by Trustee Trimm, seconded by Trustee Henry, voted upon and unanimously carried to place on file as prepared.

The following bills were presented to the commission for their audit and were approved for payment on a motion made by Trustee Trimm seconded by Trustee Henry, voted and unanimously carried:

Operation and Maintenance Abstract #9 \$19,312.02 (voucher #4888-4907, check #4925-4940)

New Business:

Gordon Eddington February 2025 Report:

1. Maintenance on equipment.
2. Running belt press – composting sludge.
3. Working on necessary changes to represent flow measurement as a means of Joint Sewer billing for the Joint Sewer Agreement.
4. Repair of water seal on grit separating system is complete and unit is running fine.
5. Discussed location of flow meter on Shortsville sewer line with Kyle (Shortsville) and George (Manchester); both thought it would work out ok. Sewer map of Shortsville indicates that all sewage comes together in the line behind the wash barn. This will be verified when the weather is warmer and manhole covers can be removed.
6. February 17, 2025 experienced 7 power outages at eh plan and main pump station due to high winds. There was an issue with one of the pumps at the pump station that is being worked on and will have to wait until warmer weather to possibly pull the pump for maintenance. Board will be updated on this status.
7. The main plant generator is approaching its life cycle (40+ years). Gordon will begin looking into project cost estimates to replace the unit.
8. Extreme cold weather is difficult on outside plant equipment
9. Plant is operating fine.

The next Joint Sewer meeting will take place on April 22, 2025 at 4:30 P.M, at the Shortsville Village Hall. Trustee Henry made a motion, seconded by Trustee Trimm to have adjourn the meeting at 4:50 P.M.

Amy Alexander
Village Clerk-Treasurer